



Proposed Code Change  
State Form 41186R

RETURN TO:  
INDIANA DEPARTMENT OF HOMELAND SECURITY  
CODE SERVICES SECTION  
302 W. Washington Street Room W246  
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 9/22/09

Code 53.32-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – ~~Dashed line through material to be deleted~~, underline material to be added)

Use second sheet for any material requiring more space.

Code Title 2009 Indiana Residential Code		Edition First Edition
Section number and title P3201.4 Building traps		Page 1 of 1
Proponent Craig Wagner	Title Chief Building Inspector/ IABO Code Comm. Member	
Address 220 W Van Buren St, Columbia City IN 46725		Phone 260-248-3111
PROPOSED CODE CHANGE (Check One)		
<input checked="" type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p><b>P3201.4 Building traps.</b> Building traps shall not be installed, <del>except in special cases where sewer gases are extremely corrosive or noxious, as directed by the building official.</del></p>		
REASON		
<p>This proposal brings forward the current amendment for this section; building traps are difficult to maintain in working order and in almost all cases are not needed.</p> <p><b>Fiscal impact:</b> no increase to the cost of construction, current amendment language.</p>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		